


New Haven Line Power Disruption and Expected Service Impacts, Feb. 2019

At approximately 12:15 AM this morning (February 19, 2019) there was a circuit breaker failure resulting in a fire at an overhead traction power substation located east of Devon Moveable Bridge in Connecticut (see image at right of an overhead substation).

This fire resulted in significant damage to the cables and wires that support the operations of the power substation (see image below).



Metro-North crews are now working to bring a *new substation* that is currently under construction, into service this week so that it can provide some of the functionality lost at the Devon substation.



Engineers are also working to introduce interim functionality at a second substation that was not scheduled to come on line until this fall.

New Haven Line customers between Stamford and New Haven should anticipate delays of 10 to 15 minutes until this interim repair work is completed, and there is a full restoration to normal operations.

We appreciate your patience while we perform these repairs.

For more information, please call 511, in CT call 1-877-690-5114 or visit www.mta.info/mnr.